

FIRE CHIEF
David Downey
11500 Sunset Gardens Rd SW
Albuquerque, NM 87121



THE ALBUQUERQUE FIRE DEPARTMENT
FIRE MARSHAL'S OFFICE

FIRE MARSHAL
Jason Garcia
724 Silver SW
Albuquerque, NM 87102

FIRE PAGE 2: FIRE DEPARTMENT FLOOR PLAN CRITERIA

PROJECT INFORMATION			REVISED 11.03.2016
Project Name	Address and/or Legal Description	BP Number	Case Number

SITE PLAN CHECK LIST				
Numbr	PASS	FAIL	REQUIREMENT	CODE REFERENCE
1	<input type="checkbox"/>	<input type="checkbox"/>	Fire 2 Plans 2 copies shall be provided and be part of the construction documents . All of the information should be provided on one sheet. In some cases projects may be too complex to fit all of the information on one sheet. If additional pages are need to complete required Fire 2 criteria. Mark them as "fire" with the corresponding number noting the order.	CITY ORD 105.4.1
2	<input type="checkbox"/>	<input type="checkbox"/>	Fire 2 designation: The plan shall be marked as "Fire2". No other designation will be accepted.	
3	<input type="checkbox"/>	<input type="checkbox"/>	Seating and equipment fixtures: The fixtures are required to be placed on the plan.	IFC 105.4.2
4	<input type="checkbox"/>	<input type="checkbox"/>	Scaled Plans: The plans shall be scaled and a true north shall be identified.	IFC 105.4.2
5	<input type="checkbox"/>	<input type="checkbox"/>	Code Data: The code data shall be noted on the plan. Address, Construction type, Occupant load, Premise Id, Sprinklered or Nonsprinklered, Square Footage, Occupancy type, Premise ID.	IFC 105.4.2
6	<input type="checkbox"/>	<input type="checkbox"/>	Room Identifiers: Each room shall be given a designation and marked on the plan.	IFC 105.4.2
7	<input type="checkbox"/>	<input type="checkbox"/>	Fire extinguishers: Fire extinguishers are required in all occupancies. Reference the IFC for distance and size requirements.	IFC 906.1
8	<input type="checkbox"/>	<input type="checkbox"/>	Means of egress: The exits, exit hardware, emergency lighting, and exit lighting/signage shall be marked on the plan.	IFC 1001.1
9	<input type="checkbox"/>	<input type="checkbox"/>	Scope of work: The scope of the work being done shall be noted on the plan.	IFC 105.4.2
10	<input type="checkbox"/>	<input type="checkbox"/>	General notes for fire protection systems: Fire protection systems shall be deferred submittals and shall be noted as such on the plan. Examples: 1) Shop drawings will be submitted to the fire marshal's office for review and approval of any installation or modification to the fire sprinkler system, fire alarm system, kitchen suppression system, or any other fire related system 2) The fire sprinkler system will be supervised when required by the 2009 International fire code.	IFC 105.4.2.1
11	<input type="checkbox"/>	<input type="checkbox"/>	Hazardous Materials: Storage, handling, and use shall be noted and shown on the plans and comply with IFC chapter 27. Hazardous materials shall include but not be limited to combustible (liquids, gas, solids), combustible fibers, cryogenic flammable, cryogenic oxidizing, consumer fireworks, explosives, flammable (Liquids, gas, solids), Oxidizers, Pyrophoric, unstable, water reactive, corrosives, toxics.	IFC 2703.1