

PAC DESIGN ISSUES LOG

New Mexico Public School Facilities Authority

PROJECT:	
DATE:	

PROJECT NUMBER:	
ASSIGNED RFM:	

1312 Basehart Rd. SE, Suite 200 Albuquerque, NM 87106-4368

Issue Number	Date Entered	State	Due Date	System	Drawing Number	Description	Responsible Party	Action Taken	Date Closed	Closed By	Status
0001	1/2/2019	Non-Critical	1/16/2019	Mech	M-602	Page is titled Mechcanical Controls, yet is blank.	ABC Engineers				LATE
0002	1/4/2019	Critical	1/9/2019	Elec		Keynotes state demo of all light fixtures. Need to clarify if all is all seeing as there are an assortment of different fixtures	ABC Engineers	Keynotes ammended to state 2x4, ceiling Florescent fixtures only.	1/15/2019	L. Peters, EE, ABC Engineers	Closed
Auto Numbering Squence		Drop Down List Calculated based upon State							Drop Down List		